

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7150-0026:224 Page 1 of 1

**CATEGORY:** Boxes/Pull Stations

**LISTEE:** Simplex, 100 Simplex Drive, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

**DESIGN:** Models 4099-9001, -9002, -9003, -9010, \*-9010TSP, \*-9010TTP, -9011, -9012, \*-9012TSP, \*-9012TTP, and -9031C non-coded addressable manual pull stations. Models 4099-9001 and -9010 are single action stations. Models 4099-9002 and -9011 are breakglass stations. Models 4099-9003 and -9012 includes a push bar which must be punched in before being able to grab and pull down the actuating handle. Model 4099-9031C is a double action station. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as manual pull stations for use with separately listed compatible fire alarm control units. Models are intended for use with listee's Models 4010, 4100, 4100U and 4020 control units (CSFM Listing Nos. 7170-0026:226, 7165-0026:160 or 7170-0026:187, 7170-0026:250 or 7165-0026:251 and 7165-0026:178). Model 4099-9013C is intended for use with Model 4010 control unit only. For indoor use only. Refer to listee's Installation Instruction Manual for details.

\*Rev. 09-25-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**